

From: thompsondavid1952@gmail.com To: Lennon, Beth Date: 25/05/2016 10:38:25 Subject:
Re: 20 Redoubt Way, Dymchurch - Y16/0398/SH -----

Dear Beth,

I can confirm that finished floor levels of the extension will be a the same height / no lower than existing

Regards,
david

David Thompson
Architectural Services
mob 07932676769
www.architectural.uk.com

On 25 May 2016 at 10:12, <Beth.Lennon@shepway.gov.uk> wrote:

Dear David

I am writing in regard to your planning application 20 Redoubt Way, Dymchurch.
Since the site is within flood zones 2 & 3 as designated by the Environment Agency,
confirmation of the finished floor levels of the proposed extension are needed.

Can you confirm that the finished floor levels of the proposed extension would be no lower than the existing floor levels? If the finished floor levels would be lower than existing then you will need to provide a drawing showing that the finished floor levels will be 300mm above the estimated flood level.

Kind regards

Beth Lennon

Planning Officer

Development Control

T: 01303 853298

Shepway District Council, Civic Centre,


Castle Hill Avenue, Folkestone, Kent, CT20 2QY

E: beth.lennon@shepway.gov.uk

Please click [here](#) for information regarding the [pre-application planning advice service](#) we offer at Shepway District Council.

www.shepway.gov.uk

Follow us on [Twitter](#) and [Facebook](#)



The contents and any attachments of this e-mail message are confidential and intended only for the named addressees. If you have received it in error, please advise the sender immediately by return email and then delete it from your system. Any unauthorised distribution or copying of this transmission, or misuse or wrongful disclosure of information contained in it, is strictly prohibited. Shepway District Council cannot accept liability for any statements made which are clearly the sender's own and not expressly made on behalf of the council. All email to and from the council may be monitored in accordance with the council's policies.

This email has been scanned by Netintelligence
<http://www.netintelligence.com/email>
