

Memorandum

To: Rob Allen

CC:

From: Wai Tse

Date: 20/07/2016

**Re: Y16/0463/SH - Shepway Resource Centre, Military Road,
Folkestone, Kent, CT20 3SP.**

Environmental Health is satisfied with the methodology and results of the noise impact assessment. It also agrees with the proposed mitigation in section 5.0.

Properties with facades overlooking and adjacent to B206063 Military Road (as indicated in Appendix 02) must be fitted with:

- Enhanced double glazing rated ≥ 38 dB R_{w+C}
- Acoustic Wall Vents rated ≥ 44 dB $D_{n,e,w}$ open position.

For room-in-roof constructions, they should have:

- Double boarded ceilings/walls and also double board “cheek” walls to dormer windows overlooking the surrounding road network.

To protect garden amenity:

- A 1.8 meter high solid timber fence/wall should have a superficial mass of at least 10 Kg/m² and panels should be rigidly mounted and there should be no gaps between adjacent panels, or the barrier and the ground. Location as specified under appendix 02. The fence should be designed (e.g. through the use of cover slips) so that gaps do not develop between abutting panels through warping or shrinking.