

# Memorandum

**To: Wendy Simpson**

**CC:**

**From: Wai Tse**

**Date: 07/03/17**

**Re: 17/0232/SH - Cautley House - demolition notice application**

---

Environmental Health has no objection regarding the granting of this application, subject to the additional conditions:

- The asbestos survey report and associated paperwork to confirm the removal of all asbestos related material from site, must be made available to officers of the local planning authority, if requested.
- All mitigation within the demolition method statement must be adopted and implemented.
- The proposed hours of working are in compliance with Shepways permitted construction hours.