

Memorandum

To: Wendy Simpson

CC:

From: Wai Tse

Date: 01/08/17

Re: Y17/0785/SH - ERECTION OF A SINGLE STOREY REAR EXTENSION TO ENLARGE THE HOT FOOD TAKE-AWAY (CLASS A5).

Environmental Health has no objections to the granting of this planning application subject to the following conditions:

- The proposed condenser unit is to be fitted on to anti-vibration mounts.
- The proposed condenser unit is to be surrounded by a protective guard, with acoustic properties to minimize the noise.

Reason: To protect the amenities of nearby residential premises.