

Symbol	Quantity	Article number
	3	BVP650 T25 1 xLED70-4S/740 DX10 (41Wx7000lm)
	2	LumiStreet BGP213 LED75-4S DX10 BL2
	1	Ledinaire floodlight mini BVP154 LED21/840 PSU 20W VWB CE
	1	CoreLine LED WT120C G2 LED40S/840 L1200mm - 4000LM

Mounted heights assumed and indicated adjacent to the individual luminaires with tilt angles.

Calculation Summary base on maintenance factor of 0.79								
Label	Units	Avg	Min	Max	Min/Avg	Height	Grid Points	UWLR
Main Carpark	Lux	23.6	6.3	62.7	0.27	0m	1.5m	0%

P2	ISSUED FOR INFORMATION	KDT	DH	DEC 2021
P1	ISSUED FOR INFORMATION	KDT	DH	DEC 2021
Rev	Drawing Revision	Drawn	Checked	Date

Status:

FOR INFORMATION



Services Consultants

Engineering Services Partnership Limited

e-mail: esp@espltd.co.uk
 Web: www.espltd.co.uk

- | | |
|--|--|
| <p>Croydon Office
 Sunley House,
 4 Bedford Park,
 Croydon, CR0 2AP
 Tel: +44 (0)20 8662 2288</p> | <p>Edinburgh Office
 CBC House,
 24 Canning Street,
 Edinburgh, EH3 8EG
 Tel: +44 (0)131 272 2788</p> |
| <p>Manchester Office
 53 King Street,
 Manchester, M2 4LQ
 Tel: +44 (0)161 359 4662</p> | <p>Peterborough Office
 11 Swan Court, Cynnet Park,
 Hampton,
 Peterborough, PE7 8GX
 Tel: +44 (0)1733 312373</p> |

Clients:

THE
CO-OPERATIVE
GROUP

Job Title

CO-OP
SELLINDGE

Drawing Title

PROPOSED EXTERNAL LIGHTING

Drawing Number: 5771/E/100			Revision: P2	
Designed:	SIGNIFY	Cad:	KDT	Checked By: DH

All information contained upon this drawing remains the property of Engineering Services Partnership Limited and may not be copied part whole without written permission.