

Installation Type	Unit of Measure	Capacity/Flow rate (1)	Use Factor (2)	Fixed use (litres/person/day) (3)	Litres/person/day = [(1)x(2)] + (3) (4)
WC (single flush)	Flush Volume (litres)		4.42	0.00	0
WC (dual flush)	Full flush Volume (litres)	4.5	1.46	0.00	6.57
	Part flush Volume (litres)	3	2.96	0.00	8.88
WC (multiple fittings)	Average effective flushing Volume (litres)		4.42	0.00	0
Taps (excluding kitchen/utility room taps)	Flow rate (litres/min)	5.00	1.58	1.58	9.48
Bath (where shower also present)	Capacity to overflow(litres)	156.00	0.11	0.00	17.16
Shower (where bath also present)	Flow Rate(litres / minute)	6.00	4.37	0.00	26.22
Bath Only	Capacity to overflow(litres)		0.50	0.00	0
Shower Only	Flow Rate (litres/minute)		5.60	0.00	0
Kitchen/Utility room sink taps	Flow rate (litres/minute)	13.00	0.44	10.36	16.08
Washing Machine	(Litres/kg dry load)	6.30	2.1	0.00	13.23
Dishwasher	(Litres/place setting)	4.50	3.6	0.00	16.20
Waste disposal unit	(Litres/use)	☐ Present	3.08	0.00	0
Water Softener	(Litres/person/day)		1.00	0.00	0
	(5)	Total Calculated use (litres/person/day) =SUM(column 4)			113.82

	(6)	Contribution from greywater (litres/person/day)	0
	(7)	Contribution from rainwater (litres/person/day)	0
	(8)	Normalisation factor	0.91
	(9)	Total internal water consumption = [(5)-(6)-(7)]x(8) (litres/person/day)	103.58
	(10)	External water use	5.0
	(11)	Total water consumption (Building Regulation 17.K) =(9)+(10)(litres/person/day)	108.6

Installation Type	Make/Model (mandatory)	Litres/Person/Day
WC (dual flush)	Debba Cistern CC BI 4.5/3L (UK) White (A34199C00F)	15.45
Taps	Calista 1TH Basin Mixer (TAP002)	9.48
Baths (shower(s) present)	Roca Contesa A2358KN000	17.16
Showers (bath(s) present)	Aqualiser 479103	26.22
Kitchen Taps	Franke Zeno Tap (101.0483.874)	16.08
Washing Machines	AEG or Electrolux	13.23
Dishwasher	AEG or Electrolux	16.20



©Water Research Centre Limited 2025

[Terms and Conditions](#)
[System Requirements](#)